










**Town of Randolph
Imagination Station Playground**

ID	Location	Floor	Room	Element	Type	Photo	Issues	Current Measure	Recommendations	Quantity	Price	Cost Estimation
Approach and Entrance												
Off-Street Parking Lot or Garage												
1	Parking Lot	Ext.		Off-Street Parking Lot or Garage	Visitor		Total # of parking Total # of designated accessible parking spaces Total # of designated van accessible spaces Sign does not have the designation "Van Accessible" Sign bottom < 60" above finished grade	2 1 1 - -	Add the designation "Van Accessible" to the sign located at the van accessible space. At both accessible parking spaces, locate signs with the bottom of the signs 60" min. above the ground measured to the bottom of the sign and 96" max. measured to the top of the sign. Re-stripe faded parking space lines at accessible spaces as needed.	1	-	\$0
Access to Goods and Services												
Picnic Tables												
2	Inside Playground	Ext.		Picnic Tables			Number of accessible seating spaces Toe or knee clearance at table not provided	0 -	Provide at least one picnic table with top between 28"- 34" above the ground and 27" clear height underneath.	1	-	\$0
3	Picnic Tables by Gazebo	Ext.		Picnic Tables	N/A		Number of accessible seating spaces Toe or knee clearance at table not provided Picnic table not on an accessible route	0 - -	Provide at least one picnic table with top between 28"- 34" above the ground and 27" clear height underneath. Ensure that the picnic table is connected to an accessible route.	4	-	\$0
4	By Playground	Ext.		Picnic Tables	N/A		Number of accessible seating spaces Toe or knee clearance at table not provided Picnic table not on an accessible route	0 - -	Provide at least one picnic table with top between 28"- 34" above the ground and 27" clear height underneath. Ensure that the picnic table is connected to an accessible route.	1	-	\$0

**Town of Randolph
Imagination Station Playground**

ID	Location	Floor	Room	Element	Type	Photo	Issues	Current Measure	Recommendations	Quantity	Price	Cost Estimation
Benches												
5	Bench in Playground Older Area	Ext.		Benches	N/A		No accessible route to one bench in this area	-	Provide an accessible route to at least one bench in this area.	1	-	\$0
6	Bench by Gazebo	Ext.		Benches	N/A		No accessible route to one bench in this area	-	Provide an accessible route to at least one bench in this area.	1	-	\$0
Play and Sport Areas												
Play Areas												
7	Playground Older Age Area	Ext.		Play Areas	N/A		Accessible route not provided around playground Accessible route not provided at play components	- -	Install an accessible route to and around the playground. Provide a compliant impact-attenuating surface under and around the play components.	1	-	\$0
8	Playground Tot Area	Ext.		Play Areas	N/A		Accessible route not provided at play components	-	Provide a compliant impact-attenuating surface under and around the play components.	1	-	\$0
Best Practice												

**Town of Randolph
Imagination Station Playground**

ID	Location	Floor	Room	Element	Type	Photo	Issues	Current Measure	Recommendations	Quantity	Price	Cost Estimation
Benches												
9	Bench by Gazebo	Ext.		Benches	N/A				Recommend providing a 36" min. by 48" min. stable, firm and slip-resistant surface adjacent to at least one (1) bench in the park at each location where benches are provided.	1	-	\$0