


**Town of Randolph**  
**Moulton Street Parking Lot**

ID	Location	Floor	Room	Element	Type	Photo	Issues	Current Measure	Recommendations	Quantity	Price	Cost Estimation
1	Parking Lot	Ext.		Off-Street Parking Lot or Garage	N/A		Total # of parking Total # of designated accessible parking spaces Total # of designated van accessible spaces	22 0 0	Provide a van accessible parking space, that is 96" wide min. with an access aisle that is 96" wide min. Provide signage with the International Symbol of Accessibility (ISA) and the designation "Van Accessible". Ensure the bottom of the sign is 60" min. above the ground and the top 96" max. above the ground.	1	-	\$0